

2019-2020 HINCHINBROOK SHIRE COUNCIL - SWIM DATA											
Year	Organisation	Scheme ID	Scheme	Scheme Long Name	Scheme Type	KPI Code	Swim Code	Indicator Title	Value	Units	Comments
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.4a	AS1	Number water treatment plants: providing full treatment	4	Count	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.1	AS2	Length water mains	268.3	km	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.4b	AS47	Capacity of water treatment plants	13.7	ML/day	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.7	AS48	Total potable water storage volume	33.9	ML	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.23	AS56	Volume water lost: potable water	286.5	ML	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG4.5	AS8	Water main breaks per 100 km water main	13	per 100 km water main	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG4.12	CS10	Water service complaints per 1000 connections	53.7	per 1000 connections	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	5.1	per 1000 connections	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	59.8	per 1000 connections	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG4.7	CS17	Average frequency unplanned interruptions: water	123.5	per 1000 connections	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.13	CS2	Connected residential properties: water	4.248	000s	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.14	CS3	Connected non-residential properties: water	0.999	000s	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG4.8a	CS66	Percent CSS response target met: water incidents	94	%	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG4.10	CS9	Water quality complaints per 1000 connections	1	per 1000 connections	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG4.1(value	PR3	Fixed charge: water value	377.2	\$/annum	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG4.1(text	PR5	Fixed charge: water description	a 20mm w	Text	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.8	WA1	Volume water sourced: surface water	310.8	ML	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.9a	WA2	Volume water sourced: groundwater	1637.8	ML	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.5	WA201	Maximum daily demand	10.3	ML/day	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.21	WA223	Volume all water imported: internal and external	NR	ML	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.22	WA224	Volume all water exported: internal and external	0	ML	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.6a	WA225	Volume potable water produced at a water treatment plant	1948.6	ML	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.17a	WA32	Volume potable water supplied: residential	989.8	ML	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.18a	WA34	Volume potable water supplied: non-residential	510	ML	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.10	WA61	Volume water sourced: desalination marine water	NR	ML	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG1.12	WA7	Volume water sourced: all	1948.6	ML	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.10a	WS11	Water restriction duration: PWCM	366	days	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.10b	WS12	Water restriction duration: Level 1	366	days	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.10e	WS15	Water restriction duration: Level 4	NR	days	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.10f	WS16	Water restriction duration: Level 5	NR	days	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertake	yes	yes/no	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 1	yes	yes/no	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	6	1,2,3,4,5,6	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.13	WS23	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
2020	Hinchinbrook Shire Council	1253	Hinchinbrook Water	Hinchinbrook Potable Water Supply Area	Potable water scheme	QG2.3	WS3	Available contingency supplies	yes	yes/no	All areas of the shire water reticulation scheme are interconnected to each other allowing emergency supply to come from several areas. All supply areas have minimum dual pumping systems with spares kept on site. Also have access to the Herbert River supply that can be increased in the case of emergency. These supply changes can be put in place with 3-4 hours if required.
2020	Hinchinbrook Shire Council	1047	Hinchinbrook Sewerage	Hinchinbrook Sewerage Service Area	Sewerage scheme	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	2.8	per 100 km sewer mains	

2020	Hinchinbrook Shire Council	1047	Hinchinbrook Sewerage	Hinchinbrook Sewerage Service Area	Sewerage scheme	QG1.3	AS4	Number sewage treatment plants	2	Count	
2020	Hinchinbrook Shire Council	1047	Hinchinbrook Sewerage	Hinchinbrook Sewerage Service Area	Sewerage scheme	QG1.2	AS5	Length sewerage mains and channels	108	km	
2020	Hinchinbrook Shire Council	1047	Hinchinbrook Sewerage	Hinchinbrook Sewerage Service Area	Sewerage scheme	QG4.13	CS11	Sewerage service complaints per 1000 connections	3.2	per 1000 connections	
2020	Hinchinbrook Shire Council	1047	Hinchinbrook Sewerage	Hinchinbrook Sewerage Service Area	Sewerage scheme	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	1.1	per 1000 connections	
2020	Hinchinbrook Shire Council	1047	Hinchinbrook Sewerage	Hinchinbrook Sewerage Service Area	Sewerage scheme	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	4.2	per 1000 connections	
2020	Hinchinbrook Shire Council	1047	Hinchinbrook Sewerage	Hinchinbrook Sewerage Service Area	Sewerage scheme	QG1.15	CS6	Connected residential properties: sewerage	2.347	000s	
2020	Hinchinbrook Shire Council	1047	Hinchinbrook Sewerage	Hinchinbrook Sewerage Service Area	Sewerage scheme	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	90.1	%	
2020	Hinchinbrook Shire Council	1047	Hinchinbrook Sewerage	Hinchinbrook Sewerage Service Area	Sewerage scheme	QG1.16	CS7	Connected non-residential properties: sewerage	0.494	000s	
2020	Hinchinbrook Shire Council	1047	Hinchinbrook Sewerage	Hinchinbrook Sewerage Service Area	Sewerage scheme	QG4.2(valu	PR31	Fixed charge: sewerage value	773.5	\$/annum	
2020	Hinchinbrook Shire Council	1047	Hinchinbrook Sewerage	Hinchinbrook Sewerage Service Area	Sewerage scheme	QG4.2(text	PR40	Fixed charge: sewerage description	Amount listed	Text	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.4a	AS1	Number water treatment plants: providing full treatment	4	Count	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.1	AS2	Length water mains	268.3	km	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.6	AS39	Sewerage mains breaks/chokes per 100 km sewer main	2.8	per 100 km sewer mains	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.3	AS4	Number sewage treatment plants	2	Count	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.4b	AS47	Capacity of water treatment plants	13.7	ML/day	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.7	AS48	Total potable water storage volume	33.9	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.2	AS5	Length sewerage mains and channels	108	km	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.23	AS56	Volume water lost: potable water	286.5	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.5	AS8	Water main breaks per 100 km water main	13	per 100 km water main	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.12	CS10	Water service complaints per 1000 connections	53.7	per 1000 connections	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.13	CS11	Sewerage service complaints per 1000 connections	3.2	per 1000 connections	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.14	CS12	Water and sewerage billing and account complaints per 1000 connections	5.7	per 1000 connections	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.11	CS13	Water and sewerage complaints (all) per 1000 connections	62.1	per 1000 connections	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.7	CS17	Average frequency unplanned interruptions: water	123.5	per 1000 connections	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.13	CS2	Connected residential properties: water	4.248	000s	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.14	CS3	Connected non-residential properties: water	0.999	000s	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.15	CS6	Connected residential properties: sewerage	2.347	000s	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.9a	CS65	Percent CSS response target met: sewerage incidents	90.1	%	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.8a	CS66	Percent CSS response target met: water incidents	94	%	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.16	CS7	Connected non-residential properties: sewerage	0.494	000s	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.10	CS9	Water quality complaints per 1000 connections	1	per 1000 connections	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.9	FN1	Revenue: all (NPR) water	3795	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.6	FN10	Nominal written down replacement cost: fixed sewerage assets	14393	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.11	FN11	Costs: operating water per connection	278.25	\$/connection	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.12	FN12	Costs: operating sewerage per connection	474.13	\$/connection	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.1	FN14	Capital expenditure: water supply	3888	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.2	FN15	Capital expenditure: sewerage	437	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.10	FN2	Revenue: all (NPR) sewerage	2540	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.3	FN26	Capital works grants: water	1000	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.4	FN27	Capital works grants: sewerage	0	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.11a	FN32	Costs: operating water (NPR)	1460	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.12a	FN33	Costs: operating sewerage	1347	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.21	FN49	Costs: any other water	844	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.22	FN50	Costs: any other sewerage	579	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.7	FN74	Current replacement costs: fixed water assets	45319	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.8	FN75	Current replacement costs: fixed sewerage assets	30586	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.13	FN76	Costs: maintenance water	380	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.14	FN77	Costs: maintenance sewerage	893	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.15	FN78	Current cost depreciation: water	844	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.16	FN79	Current cost depreciation: sewerage	579	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.17	FN80	Previous 5 year average annual renewals expenditure: water	499	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.18	FN81	Previous 5 year average annual renewals expenditure: sewerage	591	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.19	FN82	Forecast 5 year average annual renewals expenditure: water	750	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.20	FN83	Forecast 5 year average annual renewals expenditure: sewerage	600	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG3.5	FN9	Nominal written down replacement cost: fixed water assets	24404	\$,000	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.1(valu	PR3	Fixed charge: water value	377.2	\$/annum	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.2(valu	PR31	Fixed charge: sewerage value	773.5	\$/annum	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.2(text	PR40	Fixed charge: sewerage description	Amount listed	Text	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.3	PR47	Annual bill based on 200kL/a: water+sewerage	1356.7	\$	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.4	PR48	Typical residential bill: water+sewerage	1402.65	\$	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG4.1(text	PR5	Fixed charge: water description	a 20mm w	Text	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.8	WA1	Volume water sourced: surface water	310.8	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Coun	Hinchinbrook Shire Council WSP-wide	WSP	QG1.9a	WA2	Volume water sourced: groundwater	1637.8	ML	

2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.5	WA201	Maximum daily demand	10.3	ML/day	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.21	WA223	Volume all water imported: internal and external	0	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.22	WA224	Volume all water exported: internal and external	0	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.6a	WA225	Volume potable water produced at a water treatment plant	1948.6	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.11	WA26	Volume recycled sewage supplied: all	611.7	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.17a	WA32	Volume potable water supplied: residential	989.8	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.18a	WA34	Volume potable water supplied: non-residential	510	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.10	WA61	Volume water sourced: desalination marine water	0	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.12	WA7	Volume water sourced: all	1948.6	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.17b	WA91	Volume raw-PT water supplied: residential	0	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.18b	WA92	Volume raw-PT water supplied: non-residential	0	ML	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG1.20	WF1	Total full-time equivalent water+sewerage employees	15	FTEs	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.10a	WS11	Water restriction duration: PWCM	366	days	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.10b	WS12	Water restriction duration: Level 1	366	days	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.10c	WS13	Water restriction duration: Level 2	0	days	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.10d	WS14	Water restriction duration: Level 3	0	days	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.10e	WS15	Water restriction duration: Level 4	NR	days	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.10f	WS16	Water restriction duration: Level 5	NR	days	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.11a	WS17	Has asset management planning been undertaken in the last 10 yrs?	yes	yes/no	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.11b	WS18	Has drought management planning been undertaken in the last 10 yrs?	yes	yes/no	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.11c	WS19	Has water demand forecasts been developed or reviewed in the last 5 yrs?	yes	yes/no	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.11d	WS20	Has assessment of key capacity constraints of water infrastructure been undertaken	yes	yes/no	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.11e	WS21	Has the timing for potential future supply augmentation been assessed in the last 10 yrs?	yes	yes/no	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.12	WS22	Months water supply remaining as at 30 June (KPI level)	6	1,2,3,4,5,6	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.13	WS23	Confidence water demand will be met: next 18 mths	high	high,fair,unsure,low,very low	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.14	WS24	Confidence water demand will be met: next 5 yrs	high	high,fair,unsure,low,very low	
2020	Hinchinbrook Shire Council	1345	Hinchinbrook Shire Council	Hinchinbrook Shire Council WSP-wide	WSP	QG2.3	WS3	Available contingency supplies	yes	yes/no	All areas of the shire water reticulation scheme are interconnected to each other allowing emergency supply to come from several areas. All supply areas have minimum dual pumping systems with spares kept on site. Also have access to the Herbert River supply that can be increased in the case of emergency. These supply changes can be put in place with 3-4 hours if required.